

Date: _____ Time: _____ E # _____

Incident Name: _____ Incident # _____

Company /

Contractor: _____ Equipment ID: _____

Agreement # _____ Equipment Make: _____

VIN/Serial # _____ Equipment Model: _____

License Plate # _____ License Plate State: _____

Operator's Full Name: _____

EQUIPMENT TYPE / ATTRIBUTES
☐ **Type 1** – 3500+ gallons
 ☐ **Type 2** – 2501 ⇒ 3500 gallons
 ☐ **Type 3** – 500 ⇒ 2500 gallons
MINIMUM EQUIPMENT REQUIREMENTS

	<i>Not all inclusive; for additional clarification refer to the agreement (SF-1449 section D).</i>		Yes	No
1	Equipment VIN/serial # matches resource order (Schedule of Items)	D.6.3.1		
2	Check-in process completed	D.6.5.3		
3	OF-296 Vehicle/Heavy Equipment Pre-use Inspection Checklist completed	D.17		
4	Agreement: One complete copy	D.8		
5	Vehicle Identification: All equipment shall have the company's name and unique identification number affixed on each side of the vehicle.	D.2.2.5		
6	Annual Certification Current: DOT #: _____ or CVSA Inspection #: _____	D.2		
7	Wheel chocks: 2 required	D.2.1.5		
8	Back-Up Alarm	D.2.1.5		
9	Brakes on all axles.	D.2		
10	Fire extinguisher: 2A 10BC, securely mounted to the vehicle, accessible to the operator and with current annual inspection tag. DATE:	D.2.2.4		
11	Hazardous Materials Compliance Pocketbook	D.2.1.4		
12	Emergency Response Guidebook	D.2.1.4		
13	Fuel spill response kit	D.2.1.4		
14	Fuel Dispensing System: Separate dispensing system for each product offered.	D.2.1.2		

VIPR Fire Equipment Incident Compliance Inspection Checklist

FUEL TENDER

	<input type="checkbox"/> Diesel (not off-road) <input type="checkbox"/> Unleaded Fuel			
15	Hoses: In good condition with no deep cracks or leaking surfaces.	D.2.1.3		
16	Hoses and Nozzles: Appropriate size for dispensing fuels. (<i>Small nozzle for unleaded and large nozzle for diesel.</i>)	D.2.1.3		
17	Meter: Certified meter to measure accurate deliveries of fuel.	D.2.1.2		
18	Internal and Pressure (I&P) Proof: 5 year Date:	D.2.1.3		
19	Visual and Leakage (VK) Test Poof: Annual Date:	D.2.1.3		
20	Emergency Shut-off: All tank control valves protected by an emergency shutoff valve.	D.2.1.3		
21	Valve Identification: Handles painted red or a decal to direct users to the emergency valve.	D.2.1.3		
22	Valves: No visible signs of leakage and equipped with fusible nuts.	D.2.1.3		
23	Wiring Covers: Electrical wiring in tank compartments covered and no exposed wire.	D.2.1.3		
24	Wiring Housing: All lights and switches in explosion proof housings.	D.2.1.3		
25	Sealed Wiring: Openings into fixtures protected with rubber grommets to seal out fuel fumes.	D.2.1.3		
26	Pricing: Per gallon prices displayed in a visible fashion.	D.2.1.6		
27	Credit Cards: Ability to accept all major credit cards and provide receipts for fuel purchases.	D.2.1.6		

☐ Equipment meets agreement specifications ☐ Equipment does not meet agreement specifications

Inspector: _____ Date: _____
Print *Sign*

Operator: _____ Date: _____
Print *Sign*

☐ Contractor given the opportunity to correct noted deficiencies (***See Remarks***) ☐ Contactor successfully corrected noted deficiencies

Inspector: _____ Date: _____
Print *Sign*

REMARKS: (*Note in detail any deficiencies, pertinent information, comments, etc.*)